Appendix – IX
B-6

C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

आज़ादी का अमृत महोत्सव

No. F6/DFS/MS/School/SZ/2025/ 316 Dated: 1/4/2025

FIRE SAFETY CERTIFICATE

Certified that the **God's Grace (South Campus) School** located at **Kanchan Kunj, Main Jaitpur Road, South of Kalindi Kunj, Madanpur Khadar, New Delhi-76,** comprised of **Ground floor only,** was granted Fire Safety Certificate (FSC) by this department vide letter no. F6/DFS/MS/School/2019/SZ/2193 dated 22.11.2019. The school building was re-inspected by Assistant Divisional Officer (M. Road) from this department on 24.03.2025 in the presence of manager and found that the building/premises has deemed complied with the fire prevention and fire safety requirements in accordance with the circular no. 3298 to 3398 dated 01.03.2011 issued by the Directorate of Education and the building **(Ground floor only)** is fit for occupancy of Group B **"Educational Building"** with effect from 1/4/2025.... renewed for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on..1/4/2025.....at New Delhi by.

GOD'S GRACE New Delhi

(Atul Garg)
Director
Delhi Fire Service
24/3/25

Copy to:-.

1. The Directorate of Education, Center Zone: Lajpat Nagar, New Delhi-110024.
2. The Principal, God's Grace (South Campus) School located at Kanchan Kunj, Main Jaitpur Road, South of Kalindi Kunj, Madanpur Khadar, New Delhi-76.

Conditions for the validity of Fire Safety Certificate:-

1. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
2. All the means of escape shall be kept free of all the type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
6. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in.